L YNX

Security System

Programming Form & Summary of Connections

ALPHA DRAFT

June 5, 1998





TABLE OF CONTENTS

DATA FIELDS	3
*56 ZONE PROGRAMMING	8
*80 POWERLINE CARRIER DEVICE PROGRAMMING	9
*81 ZONE LISTS	10
*83 SEQUENTIAL MODE	10
*84 ASSIGN ZONE VOICE DESCRIPTORS	11
VOCABULARY INDEX (for *84 Assign Zone Voice Descriptors)	11
*85 RECORD CUSTOM VOICE DESCRIPTORS	
*56 ZONE PROGRAMMING WORKSHEET	12
POWERLINE CARRIER DEVICE WORKSHEET FOR *80 and *81	14
5800 SERIES TRANSMITTER LOOP DESIGNATIONS DIAGRAM	15
SPECIAL MESSAGES	15
LYNX SUMMARY OF CONNECTIONS DIAGRAM	16

Refer to the Installation Instructions for detailed information on programming the LYNX system, including full descriptions of all data fields.

TO ENTER PROGRAMMING MODE:

- Power up, then depress [★] and [#] both at once, within 50 seconds of powering up.
 OR
- For factory defaulted system, enter: Installer Code (4 + 1 + 1 + 2) plus 8 + 0 + 0. OR
 If different Installer Code is programmed, enter: New Installer Code + 8 + 0 + 0.
 (if *98 was used to exit previously, method 1 above must be used to enter the program mode again)
- 3. Upon entry into Program mode, data field *20 will be displayed (the first data filed in the system) and both keypad LEDs will flash.

TO PROGRAM THE DATA FIELDS:

- 1. Press [*] followed by the desired field number (e.g., *21), then make the required entry.
- 2. The keypad beeps three times after entering data, then displays the next data field in sequence.
- 3. For phone number and account number fields, press [*] to end the entry if less than number maximum number of digits is entered.
- 4. To delete an entry, simply press [*] plus that field number and reenter the correct data. For phone number and account number fields *40-*44 and *94, press [*] + field number + [*].

INTERACTIVE MENU MODES:

There are six interactive menu modes as listed below. To enter these modes, first enter Program mode. While in Program mode, press [*] plus the mode number desired (e.g., *56).

*56 Zone Programming	. For programming zone characteristics, report codes, etc.
*80 Device Programming	. For programming Powerline Carrier Devices
*81 Zone List Programming	. For programming zone lists for use with Powerline Carrier Devices
*83 Sequential Mode	. For entering transmitter serial numbers
*84 Assign Zone Voice Descriptors	. For assigning voice descriptors to zones
*85 Record Custom Voice Descriptors	. For recording custom voice descriptors

TO LOAD A DEFAULT SET:

While in Program mode, press *97, then enter a number 1-5 corresponding to the default table desired. See the Installation Instructions for the default tables. Enter 0 to exit *97.

TO EXIT PROGRAMMING MODE:

- ★98 Exits programming mode and *prevents* re-entry by: Installer Code + 8+ 0 + 0. If ★98 is used to exit programming mode, system must be powered down, then press [*] and [#] within 50 seconds of power up to re-enter programming mode.
- ★99 Exits programming mode and *allows* re-entry by: Installer Code + 8 + 0 + 0 or: Power-up, then press [*] and [#] within 50 seconds of power up.

LYNX

DATA FIELDS

Field	Function	Programmed Values [] = Table 1 Default Values						
SYST	EM SETUP (★ 20- ★ 30)							
*20	INSTALLER CODE	Enter 4 digits, 0–9						
*21	QUICK ARM ENABLE	† [1] 0 = no; 1 = yes						
*22	KEYPAD BACKLIGHT TIMEOUT	[0] 0 = none (backlighting always on); 1 = backlight off after 10secs						
*23	FORCED BYPASS	t [0] 0 = none; 1 = bypass open zones UL installations = 0						
*24	RF HOUSE ID CODE	[10] 00 = disable all wireless keypad usage; 01–31 = 5827house ID						
*25	POWERLINE CARRIER DEVICE HOUSE CODE	[0] 0 = A; 1 = B, 2 = C, 3 = D, 4 = E, 5 = F, 6 = G, 7 = H, 8 = I, 9 = J, #10 = K, #11 = L, #12 = M, #13 = N, #14 = O, #15 = P						
*26	CHIME BY ZONE	templified 1 1 1 1 1 1 1 1 1						
*27	REAL TIME CLOCK DISPLAY	[] † [1] 0 = no; 1 = yes, display time on keypad						
*29	DAYLIGHT SAVING TIME START/END MONTH	[4, 10] Start End 1-9, #+10,#+11,#+12. Enter 0,0 if no daylight savings time used.						
*30	DAYLIGHT SAVING TIME START/END WEEKEND	Start End 0 = disable; 1=first; 2=second; 3=third; 4=fourth; 5=last; 6=next to last; 7=third from last						
ZONE	E SOUNDS AND TIMING (★ 31- ★ 39)							
⊁31	SINGLE ALARM SOUNDING/ZONE	1 = yes, limit once per arming period; 0 = no limit; UL installations = 0						
★32	FIRE SOUNDER TIMEOUT							
*33	ALARM BELL TIMEOUT	† [1]						
		0 = none; 1=4 min; 2=8 min; 3=12 min; 4 = 16 min; UL installations = 1 (4 min) minimum						
† Enti	† Entry of a number other than one specified will give unpredictable results.							

rieid	runction P	rogrammed values [] = rable i Delauit value
*34	EXIT DELAY	[70] 1 1 1 1 1 1 1 1 1
* 35	ENTRY DELAY 1 (zone type 01)	time (in seconds):
* 36	ENTRY DELAY 2 (zone type 02)	00-99 = entry delay 2 time (in seconds); UL installations = 50 seconds max.
*37	AUDIBLE EXIT WARNING / QUICK EXIT	Exit Warn Quick Exit 0 = no; 1 = yes
*38	CONFIRMATION OF ARMING DING	† [0] 0 = no; 1 = yes (when armed by self-contained keypad or RF) 2 = yes (when armed by RF keypad only).
* 39	POWER UP IN PREVIOUS STATE	t [1] 0 = no; 1 = yes; UL installations = 1
† Entr	y of a number other than one specified v	vill give unpredictable results.
In field	ER PROGRAMMING (* 40– * 53) ds *40, *41, *42, enter up to the number for '#'; #+13 for a pause.	er of digits shown. Do not fill unused spaces. Enter 0–9; #+11 for '⊁
*40	PABX ACCESS CODE	Enter 6 digits. If fewer than 6 digits are entered, exit by pressing ** (and press 41, if entering next field). To clear entries from field, press **40**.
*41 F	PRIMARY PHONE No.	Enter up to 20 digits; Do not fill unused spaces. If fewer than 20 digits entered, exit by pressing * (and press 42, if entering next field). To clear entries from field, press * 41*.
*42	SECONDARY PHONE No.	Enter up to 24 digits; Do not fill unused spaces. If fewer than 24 digits entered, exit by pressing * (and press 43, if entering next field). To clear entries from field, press *4.2*
Enter report To cle	ing is to be used. If only 3 digits used, exer entries from field, press ★43★_ or ★4	· · · · · · · · · · · · · · · · · · ·
		7.7.00 52.04 , 011.01.[#111] 2 0 7
ror A	cct. 123 , enter:	

Field	Function	Programmed Values	[] = Table 1 Default Value
*43	PRIMARY SUBS ACCT #	See note on previous page	
*44	SECONDARY SUBS ACCT #	See note on previous page	
*47	PHONE SYSTEM SELECT	[] † [1] If Cent. Sta. <i>IS NOT</i> on a WAT	S line: 0 = Pulse Dial; 1 = Tone S line: 2 = Pulse Dial; 3 = Tone
*48	REPORT FORMAT	[7, 0] Primary Secondary	o mio. 2 — raiso biar, o — raiso
	 0 = 3+1, 4+1 ADEMCO L/S STAN 1 = 3+1, 4+1 RADIONICS STAN 2 = 4+2 ADEMCO L/S STANDAR 3 = 4+2 RADIONICS STANDARD 	NDARD 6 or undefined DARD 7 = ADEMC ED 8 = 3+1, 4+1	ned = 4+2 ADEMCO EXPRESS O CONTACT ID REPORTING 1 ADEMCO L/S EXPANDED 1 RADIONICS EXPANDED
* 49	SPLIT/DUAL REPORTING	[0]	
		0 = Disable (Backup report only	()
A 7-dig sent to followe See In the pa AAA Where	00 = always displayed NN = 2-digit user number or zone number	1 = Alarms, Restore, Cancel 2 = All except Open/Close, Test 3 = Alarms, Restore, Cancel 4 = All except Open/Close, Test 5 = All TO PRIMARY PHONE No. 6 = All except Open/Close de, 7 = All reports . 8 = All reports 9 = All except Open/Close *88) 101 (open), 102 (close), 811 (trouble) mber depending on type of event (EEE)	TO SECONDARY PHONE No. Others Open/Close, Test All All All TO PAGING No. (Secondary) ** Alarms, Open/Close, Troubles ** Alarms, Troubles ** Alarms, Open/Close, Troubles ** Open/Close for users 5-8 or wireless arm/disarm button zones 34-41, users 1-4 and buttons 26-33 do not send open/close. that occurred
*50	15 SEC DIALER DELAY (BURG)	0 = no; 1 = yes; UL installations	s = 0
* 51	PERIODIC TEST REPORT	0 = none; 1 = 24 hours; 2 = wee in field *64)	ekly; 3 = 30 days (enter Test Code
* 52	FIRST TEST REPORT OFFSET	telefold 1 2 2 12 2 12 12 13 14 15 15 15 15 15 15 15	2 hours; 3 = 18 hours (Time to 1st ning or downloading).
*53	SESCOA/RADIONICS SELECT	[0] 0 = Radionics (0–9, B–F reporti reporting). Select 0 for all other	
* 56	ZONE PROGRAMMING	See procedure later in this form Instructions.	and refer to the Installation
† Entr	y of a number other than one specified	will give unpredictable results.	

W "#	TO PROGRAM SYSTEM STATUS, & RESTORE REPORT CODES (*59–*76, & *89): With a 3+1 or 4+1 Standard Format: Enter a code in the <i>first</i> box: 1–9, 0, B, C, D, E, or F. Enter "#+10" for 0, "#+11" for B, "#+12" for C, "#+13" for D, "#+14" for E, "#+15" for F. A "0" (<i>not</i> "#+10") in the <i>first</i> box will disable a report. A "0" (<i>not</i> "#+10") in the <i>second</i> box will result in automatic advance to the next field when programming. With an Expanded or 4+2 Format: Enter codes in <i>both</i> boxes (1st and 2nd digits) for 1–9, 0, or B–F, as described above. A "0" (<i>not</i> "#+10") in the <i>second</i> box will eliminate the expanded message for that report. A "0" (<i>not</i> "#+10") in <i>both</i> boxes will disable the report. With Ademco Contact ID Reporting: Enter any digit (other than "0") in the <i>first</i> box, to enable zone to report (entries in the <i>second</i> boxes will be ignored). A "0" (<i>not</i> "#+10") in the <i>first</i> box will disable the report. Examples: For Code 3 (single digit), enter: 3 0 For Code 3 2 (two digits), enter:									
	For Code	B 2 (Hexadecimal), enter:	#+11 2							
S\ Fie		REPORT CODES (*59–*68) Pro	Default grammed		ort codes = [00]] = Table 1 Defa	ult Value			
*!	59 EXIT ERRO	R REPORT CODE		_		s 2nd digit of the zon				
*(TROUBLE R	REPORT CODE								
*(BYPASS RE	PORT CODE								
*(AC LOSS RI	EPORT CODE								
*(S3 LOW BAT R	EPORT CODE								
*(54 TEST REPO	ORT CODE								
*(OPEN REPO	ORT CODE	††							
*(66 ARM AWAY	/STAY RPT CODE	AWAY	††	•	utomatically sent a ded or 4+2 reportin				
*(RF XMTR LO	OW BAT REPORT CODE								
*(68 CANCEL RE	PORT CODE								
RI	ESTORE REPORT	CODES (*70–*76) Default	for all res	tore repor	t codes = [00]					
*	70 ALARM RES	STORE RPT CODE		•	•	s 2nd digit of the zon panded or 4+2 report	•			
*	71 TROUBLE R	RESTORE RPT CODE								
*	72 BYPASS RE	STORE RPT CODE								
*	73 AC RESTOR	RE RPT CODE								
*	74 LOW BAT R	ESTORE RPT CODE								
*	75 RF XMTR LO	O BAT RST RPT CODE								
*	76 TEST REST	ORE RPT CODE								
*8 *8 *8	60 POWERLINE CA 61 ZONE LISTS FOI 63 SEQUENTIAL MO 64 ASSIGN ZONE V		zone are t 56): See p ocedure lat	to be used. rocedure la er in this m	See procedure la ter in this manual anual.	Carrier Devices or ter in this manual.	· chime by			

Field	Function Pro	ogrammed Values	[] = Table 1 Default Value
*87	AUX FUNCTION/ 1-BUTTON PAGING	[0] 0 = Aux key performs defined functions are sage (999-999999999999999999999999999999999	999) to pager
⊁ 88	PAGER CHARACTERS	Up to 16 digits can be entered that we pager message sent by the control (pressing AUX key [if programmed for other options regarding the paging for Instructions (fields *87, *88 and *49) feature.	either upon system event or upon or paging]; see field *87 and *49 for eature). See the Installation for full descriptions of the paging
		You do not need to fill all 16 digits (p field). To enter "*" = [#] + [11]; To enter "#" To enter 2-second pause = [#] + [13 additional delay [pause] in order to r	= [#] + 12]] (some pagers require an
⊁ 89	EVENT LOG 80% FULL RPT CODE		
*90	EVENT LOGGING	[3]	
		0 = None; 1 = Alarm/Alarm Restore; 4 = Bypass/Bypass Restore; 8 = Op <i>Example:</i> To select "Alarm/Alarm R (1 + 8); To select all, enter #15. Note: System messages are logged made.	en/Close. estore", and "Open/Close", enter 9
* 91	FUTURE USE	[0] Must be 0. If inadvertently enabled, to be sent to the central station after an	
*92	No. OF REPORTS IN ARMED PERIOD		
DOWI	NLOAD INFORMATION (*93,*94,*95)		
*93	FLEXIBLE CALLBACK	[0] 0 = No flexible callback; 1 = Last dig = Last 3 digits flexible	it flexible; 2 = Last 2 digits flexible; 3
*94	DOWNLOAD PHONE No.	Enter up to 20 digits, 0–9; #+11 for '	•
* 95	RING DETECT COUNT FOR DOWNLOADING	[0] 0 = Disable Station Initiated Downloa +10 =10, [#] +11 =11, [#] +12 =12, [#]	#] +13 =13, [#] +14 =14); 15 =
		answering machine defeat ([#] +15 =	

- *96 INITIALIZES DOWNLOAD ID, SUBSCRIBER ACCOUNT No. FOR INITIAL DOWNLOAD: No entry required.
- *97 SELECT 1 OF 5 DEFAULT OPTION SETUPS. Enter 1-5 to select from default tables 1-5. Enter 0 to abort.
- **★98** EXITS PROGRAMMING MODE AND *PREVENTS* RE-ENTRY by: Installer Code + 8+ 0 + 0. If ★98 is used to exit programming mode, system must be powered down, then press "★" and "#" within 50 seconds of power up to re-enter programming mode.
- **★99** EXITS PROGRAMMING MODE AND *ALLOWS* RE-ENTRY by: Installer Code + 8 + 0 + 0 or: Power-up, then press "★" and "#" within 50 seconds of power up.

*56 ZONE PROGRAMMING PROCEDURE

Use this mode to program zone information. Press *56 while in programming mode. **NOTE:** Entry of a number other than one specified will give unpredictable results.

A0 I

ZONE NUMBER

Enter the 2-digit zone number to be programmed: • Zone 1 = hard wire zone

[*] = Continue • Zones 2-25 = RF transmitter zones

00 = exit zone programming mode; • Zone 26-41 = RF button zones

upon exiting, the prompt "56" blinks; press [*] + any field number to go to that field.

b zt

ZONE TYPE

Enter the 2-digit zone type (zt) for this zone (see table of zone types on worksheet page 13).

[*] = Continue

[#] = Return to previous prompt

C rc

REPORT CODE

Enter the report code (rc) for this zone.

Report consists of 2 hexadecimal digits, each of which consist of 2 numerical digits (A = 10, B = 11, C = 12, D = 13, E = 14, F = 15; see Report Code description on page 6 for explanation of codes).

[*] = Continue; If this is zone 1, the system skips to the VOICE DESCRIPTOR prompt (1C)

[#] = Return to previous prompt

d i

INPUT TYPE

Enter the input type (i) for the transmitter assigned to this zone as follows:

3 = Supervised RF (RF) [*] = Continue

4 = Unsupervised RF (UR) [#] = Return to previous prompt

5 = Button type (BR)

 E l L

LOOP NUMBER

Enter the loop number (*I*) for this zone. If "L" is displayed, the serial number for this transmitter has already been entered. You can keep the serial number and skip to the VOICE DESCRIPTOR prompt, or you can continue to the DELETE SERIAL NUMBER prompt.

0 + [*] = to Delete Serial Number prompt (F)

[*] = Continue to the ENROLL MODE prompt (1A) if not enrolled, or VOICE DESCRIPTOR prompt (1C) if already enrolled.

[#] = Return to previous prompt

F

DELETE SERIAL NUMBER

0 = Keep existing number and proceed to VOICE DESCRIPTOR prompt (1C)

1 = Delete the serial number only. The system will delete the transmitter's serial number and return to the ZONE NUMBER prompt (A).

2 = Delete the serial number and all other zone parameters (zone type, report code, etc.). The system will delete the transmitter's serial number and all zone information, then return to ZONE NUMBER prompt (A).

ΙA

ENROLL MODE

0 = Skip to the VOICE DESCRIPTOR prompt (1C). If zone type is "00," then skips to DELETE SERIAL NUMBER prompt instead.

1 = Enroll now and proceed to SERIAL NUMBER prompt (1b)

Ιb

SERIAL NUMBER

Enter the transmitter's 7-digit serial number (printed on the transmitter). If you enter an incorrect digit, press the [#] key to backup to that digit and reenter the correct digit.

When all 7 digits are entered, press the [*] key. Each digit will be re-displayed, and the keypad will beep once for digits 1-6, 3 times for the last digit. If less than 7 digits are entered, the un-entered digits will display "F." If too many digits have been entered, the first 6 digits will be saved, along with the last digit that was entered (entering 123456789 yields serial number 1234569).

If the serial number is correct, press [*] again to save it and advance to the next prompt (1C) or, if the zone type is 00, will return to the DELETE SERIAL NUMBER PROMPT (F).

If the serial number is not correct, press [#], which deletes the number and returns to the ENROLL MODE prompt (1A), allowing you to reenter the number.

IC

VOICE DESCRIPTOR

0 = Skip to next zone (A)

Id vv

1 = Enter descriptor mode (existing zone descriptor will be announced, then descriptor 1 will be repeated)

DESCRIPTOR 1

Enter [#] + 2-digit vocabulary index[†] number ($\nu\nu$) of first descriptor word for this zone.

6 = accept word and advance to descriptor 2 (descriptor 2 will be announced)

8 = accept word and advance to next zone (prompt A) - zone descriptor will be announced

Press any other key to repeat the selected word

IE vv

DESCRIPTOR 2

Enter [#] + 2-digit vocabulary index[†] number (vv) of second descriptor word for this zone.

6 = accept word and advance to descriptor 3 (descriptor 3 will be announced)

8 = accept word and advance to next zone (prompt A) - zone descriptor will be announced

Press any other key to repeat the selected word

IF vv

DESCRIPTOR 3

Enter [#] + 2-digit vocabulary index[†] number (*vv*) of third descriptor word for this zone. 6 or 8 = accept word and advance to next zone (prompt A) – zone descriptor will be announced Press any other key to repeat the selected word

*80 POWERLINE CARRIER DEVICE PROGRAMMING

Use this mode to program Powerline Carrier Devices or zone lists for Chime by Zone feature. Press *80 while in programming mode. **NOTE:** Entry of a number other than one specified will give unpredictable results.

80

Powerline Carrier Device Programming

0 = Exit mode, upon which this prompt blinks. Press [*] + any field number to go to that field.

1 = Enter mode

A0 I

DEVICE NUMBER

Enter the 2-digit device number (01-08) to be programmed

[*] = Continue

00 = Exit Device Programming mode (displays blinking 80; enter * + desired data field or menu mode number)

b aa

DEVICE ACTION

Enter the 1-digit action, 0-3, for the device being programmed (current action is displayed).

0 = No response 3 = Pulse on and off

1 = Close for 2 seconds [*] = Continue

2 = Close and stay closed [#] = Return to previous prompt

C et

START EVENT TYPE (if applicable)

Enter the 1-digit start event type, 0-3, for the device being programmed.

0 = Not used 3 = Trouble 1 = Alarm [*] = Continue

2 = Fault [#] = Return to previous prompt

d zl

START ZONE LIST (if applicable)

Enter the 1-digit zone list number, 1-3, or 0 if not used, for the device being programmed.

[*] = Continue

[#] = Return to previous prompt

 \mathbf{E} zt

START ZONE TYPE (if applicable)

Enter the 2-digit start zone type for the device being programmed (see Powerline Carrier Device Worksheet for zone type/system operation codes later in this manual).

[*] = Continue

[#] = Return to previous prompt

 \mathbf{F} zl

STOP ZONE LIST (if applicable)

Enter the 1-digit zone list number, 1-3, or 0 if not used, for the device being programmed.

[*] = Continue

[#] = Return to previous prompt

IA zt

STOP ZONE TYPE (if applicable)

Enter the 2-digit stop zone type for the device being programmed (see Powerline Carrier Device Worksheet for zone type/system operation codes later in this manual).

[*] = Return to Device Number prompt (A)

[#] = Return to previous prompt

[†] See *84 ASSIGN ZONE VOICE DESCRIPTORS section for Vocabulary Index.

*81 ZONE LISTS

Use this mode to define zone lists for Powerline Carrier Devices and/or for the chime by zone feature. Press *81 while in programming mode. **NOTE:** Entry of a number other than one specified will give unpredictable results.

8 I

ZONE LIST PROGRAMMING

0 = Exit mode, upon which this prompt blinks. Press [*] + any field number to go to that field.

1 = Enter mode

A 01

ZONE LIST NUMBER

Enter the 2-digit zone list number (01-03) to be programmed (use zone list 03 for chime by zone feature).

[*] = Continue

00 = Exit mode (displays blinking 81; enter * + desired data field or menu mode number)

b *zz*

ZONE ENTRY TO LIST

Enter the 2-digit zone number (zz) to be added to this zone list.

[*] = Accept zone number and enter the next zone number

00 = Accept zone number and continue to next prompt

C

DELETE ENTIRE ZONE LIST?

0 = Don't delete; continue to next prompt

1 = Delete the current zone list

d

DELETE SPECIFIC ZONES FROM LIST?

0 = Don't delete; continue to next zone list number (prompt A 01)

1 = Continue to delete zones prompt

E

DELETE ZONES

Enter the 2-digit zone number to be deleted from the current zone list

[*] = Delete zone and enter next zone to be deleted

00 = Return to next zone list number (prompt A 01)

*83 SEQUENTIAL MODE

Use this mode to enter transmitter serial numbers. Press *83 while in programming mode. **NOTE:** Entry of a number other than one specified will give unpredictable results.

A0 I

ZONE NUMBER

Enter the 2-digit zone number of the first transmitter to have its serial number entered.

[*] = Continue; system searches for zones not yet entered, then goes to ENROLL SERIAL NUMBER prompt (C)

00 = Exit Sequential mode, upon which the prompt "83" blinks. Press [*] + any field number to go to that field.

b zz

ENROLL ZONE?

0 = return to ZONE NUMBER prompt (A 01)

1 = yes, enter serial number for this zone

С

ENROLL SERIAL NUMBER

Enter the transmitter's 7-digit serial number (printed on the transmitter). If you enter an incorrect digit, press the [#] key to backup to that digit and reenter the correct digit.

When all 7 digits are entered, press the [*] key. Each digit will be re-displayed, and the keypad will beep once for digits 1-6, 3 times for the last digit. If less than 7 digits are entered, the un-entered digits will display "F." If too many digits have been entered, the first 6 digits will be saved, along with the last digit that was entered (entering 123456789 yields serial number 1234569).

If the serial number is correct, press [*] again to save it and go to next zone to be entered (prompt b).

If the serial number is not correct, press [#], which deletes the number and returns to the ENROLL MODE prompt (1A), allowing you to reenter the number.

*84 ASSIGN ZONE VOICE DESCRIPTORS

Use this mode to assign voice descriptors for each zone. These are the descriptors that are announced when the system announces any event involving a zone number. Press *84 while in programming mode. **NOTE:** Entry of a number other than one specified will give unpredictable results.

84

ASSIGN ZONE VOICE DESCRIPTORS

0 = Exit mode, upon which this prompt blinks. Press [*] + any field number to go to that field.

1 = Enter mode



ZONE NUMBER

Enter the 2-digit zone number (zz) for which this descriptor is being assigned.

[*] = Continue to next prompt (any existing descriptors will be announced, then descriptor 1 will be repeated.)

00 = Exit Zone Voice Descriptor mode (displays blinking 84; enter * + desired data field or menu mode number)

b vv

DESCRIPTOR 1

Enter [#] + 2-digit vocabulary index number of first descriptor word for this zone.

6 = accept word and advance to descriptor 2 (descriptor 2 will be announced)

8 = accept word and advance to next zone (prompt A....zz) – zone descriptor will be announced Press any other key to repeat the selected word

C vv

DESCRIPTOR 2

Enter [#] + 2-digit vocabulary index number of second descriptor word for this zone.

6 = accept word and advance to descriptor 3 (descriptor 3 will be announced)

8 = accept word and advance to next zone (prompt A....zz) – zone descriptor will be announced Press any other key to repeat the selected word

d vv

DESCRIPTOR 3

Enter [#] + 2-digit vocabulary index number of third descriptor word for this zone.

6 or 8 = accept word and advance to next zone (prompt A....zz) – zone descriptor will be announced Press any other key to repeat the selected word

VOCABULARY INDEX

00	½ sec pause		F		M		U
	Α	14	FIRE	25	MAIN	40	UPSTAIRS
01	ALARM	15	FLOOR	26	MASTER	41	UTILITY
02	ATTIC	16	FRONT	27	MESSAGE		147
			•	28	MOTION	40	W
00	В	4-	G		•	42	WINDOW
03	BABY	17	GARAGE		0		Υ
04	BACK	18	GUN	29	OFFICE	43	YARD.
05	BASEMENT		Н		Р		
06	BATHROOM	19	HALL	30	PATIO		Z
07	BEDROOM	10	11/11	31	POOL	44	ZONES
	С		I	01		44	
08	CHECK	20	INSIDE		R	45	1 ST
00	CHLCK		J	32	ROOM	46	2 ND
	D		K		S	47	3 RD
09	DEN	21	KITCHEN	33	SHED		
10	DETECTOR	21	KIICHEN	34	SHOP	70	Custom Word #1
11	DINING		L	35	SIDE	71	Custom Word #2
12	DOOR	22	LAUNDRY		SLIDING	72	Custom Word #3
	E	23	LIBRARY	36		73	Custom Word #4
40	EMERGENCY	24	LIVING	37	SMOKE STORAGE	74	Custom Word #5
13	EMERGENCY			38		99	Blank
				39	SYSTEM		(to erase previously
							programmed word)

SYSTEM WORDS
(Announced by system
not programmable)
AC LOSS
ARMED
AWAY
BYPASSED
CHIME
DISARMED
DISARM SYSTEM
NOW
EXIT NOW
FAULT
INSTANT
LOW BATTERY
NOT
READY TO ARM
STAY

*85 RECORD CUSTOM VOICE DESCRIPTORS

Use this mode to record up to 5 custom voice descriptors for use with zone announcements. Press *85 while in programming mode. **NOTE**: Entry of a number other than one specified will give unpredictable results.

85

RECORD CUSTOM VOICE DESCRIPTORS

0 = Exit mode, upon which this prompt blinks. Press [*] + any field number to go to that field. 1 = Enter mode

A d

CUSTOM DESCRIPTOR NUMBER

Enter 7 + d + [*], where d = 0-4, each representing custom word 70, 71, 72, 73 or 74 respectively. Exitsting descriptor will be announced.

Press [#] to start recorder. Wait for beeps before speaking.

Speak the desired word clearly near the keypad microphone. Recording stops after 1.5 seconds.

6 = Accept word and ready to record next descriptor (prompt A....d)

[#] = Re-record descriptor

00 = Exit Record mode after pressing 6 (displays blinking 85; enter * + desired data field or menu mode number) Press any other key to repeat the recorded word.

★56 ZONE PROGRAMMING WORKSHEET

Fill in the required data on this worksheet, then follow the programming procedure in the Installation Instructions.

See explanation of headings on next page

Zone Description Wired Zone 1	Zone No. (a 01) 0 1	Zone Alarm rpt code Type (zt) (hex) (rc) [00] [00 00]
Duress	9 2	— — [01 00]
Keypad Panic (1 & ⋆)	9 5	[00 00]
Keypad Panic (3 & #)	9 6	[00 00]
Keypad Panic (* & #)	9 9	[06] [01 00]

	Keypad Panio	9 9		[06]	[01 00]	
Zone No. (A 01)	Zone Type (zt)	Alarm Report Code in hex (rc)	Input Type (I)	Loop No. (I)	Transmitter Serial Number	Vocabulary Index
0 2	[01]	[01 00]	[3]	[2]		[16-12-99]
0 3	[01]	[01 00]	[3]	[2]		[04-12-99]
0 4	[03]	[01 00]	[3]	[2]		[42-99-99]
0 5	[10]	[01 00]	[3]	[1]		[28-10-99]
0 6						
0 7						
0 8						
0 9						
1 0						
1 1						
1 2						
1 3						
1 4						
1 5						
1 6						
1 7						
1 8						
1 9						
2 0						
2 1						
2 2						
2 3						
2 4						
2 5						

Button Zo	Button Zones							
Zone No.		Alarm Report	Input	Loop Transmitter	Vocabulary			
(A 01)	Type (zt) [21]	Code in hex (rc) [01 00]	Type (I) [5]	No. (I) Serial Number	Index			
2 7	[22]	[01 00]	[5]	[2]				
2 8	[23]	[00 00]	[5]	[4]				
2 9	[23]	[00 00]	[5]	[1]				
3 0	[21]	[01 00]	[5]	[3]				
3 1	[22]	[01 00]	[5]	[2]				
3 2	[23]	[00 00]	[5]	[4]				
3 3	[23]	[00 00]	[5]	[1]				
3 4								
3 5								
3 6								
3 7								
3 8								
3 9								
4 0								
4 1								

EXPLANATION OF ZONE ASSIGNMENT TABLE HEADINGS

A 01 = ZONE No. Zone Numbers are 01 (wired zone), 2-25 (RF zones), 26-41 (Button zones), 92 (duress), 95, 96, 99 (panic zones).

 zt = ZONE TYPE 00 = Not Used
 06 = 24 Hr Silent
 20 = Arm-Stay

 01 = Entry/Exit #1
 07 = 24 Hr Audible
 21 = Arm-Away

 02 = Entry/Exit #2
 08 = 24 Hr Aux
 22 = Disarm

 03 = Perimeter
 09 = Fire
 23 = No Alarm

 04 = Interior Follower
 10 = Interior w/Delay
 Response

05 = Trouble Day/Alarm Night 24 = Silent Burglary

rc = ALARM REPORT CODE

Two Hex Digits. For each Hex Digit, enter: 00–09 for 0–9, 10 for A, 11 for B,12 for C, 13 for D, 14 for E, 15 for F. If "00" is entered as the first digit, there will be no report for that zone.

For Contact ID reporting, this is enabling code only. Enter any hex digit (other than 00) in

the first pair of boxes. The second pair of boxes is ignored.

i = INPUT TYPE Enter 3 for RF: Supervised RF

Enter 4 for UR: Unsupervised RF Enter 5 for BR: Button Type RF

I = LOOP NUMBER Used with 5800 RF Loop Input Devices. Record transmitter loop number.

Entries are 1-4, depending on device being used. Refer to the transmitter's instructions for

appropriate loop numbers.

POWERLINE CARRIER DEVICES WORKSHEET FOR *80, and *81.

Applicable only if Powerline Carrier Devices are to be used, or chime-by-zone feature is used.

***80 OUTPUT DEVICES**

Fill in the required data on the worksheet on below and follow the programming procedure in the Installation Instructions as you enter the data during the displays and prompts that appear in sequence.

Note: Field *25 must be programmed with a House Code.

		START either or both		S T O P either or both	
DEVICE NUMBER	ACTION (aa)	EVENT ZONE TYPE LIST (et) (zl)	ZONE TYPE SYST OP'N (zt)	RESTORE ZONE LIST (zl)	ZONE TYPE /SYST OP'N (zt)
P.L.C.D.* 01					
P.L.C.D.* 02					
P.L.C.D.* 03					
P.L.C.D.* 04					
P.L.C.D.* 05					
P.L.C.D.* 06					
SYSTEM 07 P.L.C.D.*		_			
SYSTEM 08 P.L.C.D.*					

P.L.C.D. = Powerline Carrier Device (X-10).

Where:

A = DEVICE ACTION 0 = No Response; 1 = Close for 2 sec; 2 = Close and stay closed; 3 = Pulse on and off.

ET = EVENT TYPE 0 = Not used; 1 = Alarm; 2 = Fault; 3 = Trouble.

ZL = ZONE LIST 1, 2, or 3 (from Field *81) or 0 = Not Used.

"START" ZONE LIST: Upon alarm, fault, or trouble of ANY zone on this list, device action will START. "STOP" RESTORE of ZONE LIST: Upon restore of ALL zones on this list, device action will STOP. It need not be same list as used for START.

NOTE: Do not use input type "BR" transmitters in a zone list to STOP a relay action, since these transmitters do not send restore signals.

ZT = ZONE TYPE/SYSTEM OPERATION Choices for Zone Types are:

00 = Not Used06 = 24 Hr Silent Any zone in "ZT" going into alarm, Note: 01 = Entry/Exit#1 07 = 24 Hr Audible fault, or trouble will actuate relay. 02 = Entry/Exit#2 08 = 24 Hr AuxAny zone of that type that restores 03 = Perimeter 09 = Fire Zone will stop relay action. 04 = Interior Follower 10 = Interior w/Delay 05 = Trouble Day/Alarm Night 24= Silent Burglary

Choices for System Operation are:

 20 = Arming-Stay
 38 = Chime

 21 = Arming-Away
 39 = Any Fire Alarm

 22 = Disarming (Code + OFF)
 40 = Bypassing

 31 = End of Exit Time
 42 = System Battery Low

31 = End of Exit Time 42 = System Battery Low * Or at Disarming, whichever occurs 32 = Start of Entry Time 43 = Communication Failure earlier.

33 = Any Burglary Alarm 52 = Kissoff 36 = *At Bell Timeout 58 = Duress

Note: In normal operation mode:


*81 ZONE LISTS FOR OUTPUT DEVICES

Fill in the required data on the worksheet below and follow the procedure in the installation manual as you enter the data during the displays and prompts that appear in sequence.

Note: Record desired zone numbers below. More or fewer boxes than shown may be needed, since any list may include *any* or *all* of system's zone numbers.

Zone List 1: Started or stopped by zone numbers (enter 00 to end entries).
.etc.
[28] [32]
Zone List 2: Started or stopped by zone numbers (enter 00 to end entries).
.etc.
[29] [33]
Zone List 3: Started or stopped by zone numbers AND/OR assignment of Chime zones (enter 00 to end entries)
.etc.
[02] [03]

5800 SERIES LOOP NUMBERS



SPECIAL MESSAGES

EE = DATA ENTRY ERROR (invalid field number entered while in programming mode; re-enter valid field number).


FC = Communication Failure

EA = Exit Alarm

CA = Cancel Alarm

CC = Modem Communication (system is in communication with the central station)

After powering up, **AC**, **dI** (disabled) will be displayed after approximately 4 seconds. This will revert to the Real-time Clock in approximately 1 minute, which allows PIRS, etc. to stabilize. To bypass this delay, press: [#] + [0].



165 Eileen Way, Syosset, New York 11791 Copyright © 1998 PITTWAY CORPORATION